

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE 1 OF 4 PAGES
2. AMENDMENT/MODIFICATION NO. AMENDMENT NO. 0003		3. EFFECTIVE DATE 02/02/12	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable) 11-0168
6. ISSUED BY CODE		CODE mks	7. ADMINISTERED BY (If other than Item 6) CODE See Item 6	
Officer in Charge of Construction MCI-East 1005 Michael Road Camp Lejeune, NC 28547-2521				
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)			(X)	9A. AMENDMENT OF SOLICITATION NO. N40085-11-R-0168
			X	9B. DATED (SEE ITEM 11) 01/30/12
				10A. MODIFICATION OF CONTRACT/ORDER NO.
				10B. DATED (SEE ITEM 11)
CODE	FACILITY CODE			

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a) By completing items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

**13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS.
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor is not, is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

11-0168, Repair Elevated Potable Water Storage Tank, STC510

1. Question: Specification Section 02 82 33.13 20 Removal/Control and Disposal of Paint with Lead is included in this project. We do not find a Lead Paint Report. Can you tell me if there has been any lead paint testing and if so can a report be provided.

1. Answer: Per the attached document (March 2009 Report) there is no lead paint present.


Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR		16B. UNITED STATES OF AMERICA	16C. DATE SIGNED
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

ELEVATED TANK WASHOUT INSPECTION REPORTS

**MARINE CORPS BASE
CAMP LEJEUNE, NORTH CAROLINA**

Job Order No: Study 09-01



3-25-09

**PREPARED BY:
HOBBS, UPCHURCH & ASSOCIATES, P.A.
300 S.W. BROAD STREET
SOUTHERN PINES, NC 28387**

MARCH 2009



UTILITY SERVICE co., inc

Camp Lejeune, N.C.

**Elevated Tanks Washout Inspections
Report**

500KG STC-510 Camp Geiger Tank

300KG S380 Berkley Manor Tank

300KG SFC314 French Creek Tank

250KG SM623 Camp Johnson Tank

300KG S5 Hadnot Point 200 Tank

250KG SRR114 Rifle Range Tank

200KG S2323 Paradise Point Tank

250KG SBB242 Courthouse Bay Tank

PREPARED BY: SCOTTY WILKINS

March 2009

"Confidential Information"

(Not to be Duplicated or Redistributed Without Approval)

Tank Details: 500,000 Gallon Elevated – STC.510 camp Geiger Tank

Capacity:	<u>500,000 Gallon</u>	Style:	<u>Elevated</u>
No. Legs:	<u>6 Six</u>	Leg Style:	<u>Tubular</u>
No. Struts:	<u>2 Two (sets)</u>	Strut Style:	<u>I-Beam</u>
Riser Size:	<u>60" diameter</u>	Const. Style:	<u>Welded</u>
Height:	<u>147.5' to H.W.L.</u>	Year Erected:	<u>1991</u>
Int. Coating:	<u>Epoxy</u>	Ext. Coating:	<u>Urethane</u>
Int. Mil Thickness:	<u>8-12 D.F.T.</u>	Ext. Mil Thickness:	<u>8-14mils D.F.T.</u>
Int. Lead Presence:	<u>Negative</u>	Ext. Adhesion:	<u>Poor to Fair</u>
Int. Adhesion:	<u>Poor-Fair</u>	Ext. Lead Presence:	<u>Negative</u>
Latitude:	<u>N34 degrees 44.252</u>	Replacement Cost of Tank:	<u>\$1,250,000.00</u>
Longitude:	<u>W077 degrees 27.446</u>	Safety Equip.	<u>Yes</u>