

**NAVFAC
SPECIFICATION**

**WO #5334131
Install Voltage Regulating
Equipment**

AMENDMENT #0001

IMPORTANT

This amendment should be acknowledged when your proposal is submitted. Failure to acknowledge the amendment may constitute grounds for rejection of the proposal.

If your proposal has been submitted prior to the receipt of this amendment, acknowledgement should be made by telegram, which should state whether the price contained in your proposal is to remain unchanged, is to be decreased by an amount, or is to be increased by an amount. The acknowledgement must be received prior to proposal opening time.

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT		1. CONTRACT ID CODE	PAGE	OF PAGES
			1	1

2. AMENDMENT/MODIFICATION NO. 0001	3. EFFECTIVE DATE 9/6/2011	4. REQUISITION/PURCHASE REQ. NO. 5334131	5. PROJECT NO. (If applicable) 5334131
---------------------------------------	-------------------------------	---	---

6. ISSUED BY CG MCAS Cherry Point FACILITIES, ROICC B-163, CURTIS ROAD PSC BOX 8006 CHERRY POINT, NC 28533	Code N40085	7. ADMINISTERED BY (If other than item 6.)	Code
--	-------------	--	------

8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code) AMENDMENT MUST BE ACKNOWLEDGED WITH YOUR PROPOSAL	<input checked="" type="checkbox"/>	9A. AMENDMENT OF SOLICITATION PROJECT #5334131
		9B. DATED (SEE ITEM 11) 1/28/2010
	<input type="checkbox"/>	10A. MODIFICATION OF CONTRACT/ORDER NO.
		10B. DATED (SEE ITEM 13)

CODE FACILITY CODE

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in item 14. The hour and date specified for receipt of Offers is extended is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning 1 copy of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (if required)

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

- A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14. ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
- B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATION CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103 (b).
- C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
- D. OTHER: (specify type of modification and authority)

E. IMPORTANT: Contractor is not is required to sign this document and return **original** to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

5334131 Install Voltage Regulating Equipment, MCAS Cherry Point North Carolina

Refer to the solicitation specification section 01 90 00 - SCOPE OF WORK and reconfigure the solicitation into a base bid item and three additive bid items. See attached sheet for additional information and requirements.

Final Proposals will be due on 08 September 2011 no later than 1400.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR (Same as Item 8)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY	16C. DATE SIGNED
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

Refer to the solicitation specification section 01 90 00 - SCOPE OF WORK and reconfigure the solicitation into a base bid item and three additive bid items.

The Base Bid is to include the following 01 90 00 paragraphs:

- 4.1 NEW EMCS METERS (Paragraphs 4.1.1, 4.1.2, 4.1.3)
- 4.2.1 ADDING NEW METERS TO SCADA USING JCI BACnet - Software Programming
- 4.3 UPGRADE SCADA HARDWARE AND SOFTWARE (Paragraphs 4.3.1, 4.3.2, 4.3.3, 4.3.4)

Add new paragraph 4.2.3 to the Scope Of Work and the base bid as follows:

4.2.3 SOLAR PV SCADA METER DATA: Using BACnet/IP, access the existing EMCS energy meters which meter the PV systems on Buildings 1, 159, 194 and 1016 and add them to the SCADA system. Provide a new HMI page which displays the voltage, current and power output for each meter.

Additive Bid Item 1 is to include the following 01 90 00 paragraph:

- 4.2.2 ADDING NEW METERS TO SCADA USING JCI BACnet - BRIDGE TO FRCE EMCS

Additive Bid Item 2 is to include the following 01 90 00 paragraph:

- 4.4.1 UPGRADE EMCS HARDWARE - ADN-1

Additive Bid Item 3 is to include the following 01 90 00 paragraph:

- 4.4.2 UPGRADE EMCS HARDWARE - ADN-2