

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE 1 OF 3 PAGES
2. AMENDMENT/MODIFICATION NO. AMENDMENT NO. 0004	3. EFFECTIVE DATE 9-9-11	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable) 10-0014	
6. ISSUED BY CODE sdb	7. ADMINISTERED BY (If other than Item 6) CODE See Item 6			
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code) Officer in Charge of Construction MCI-East 1005 Michael Road Camp Lejeune, NC 28547-2521			(X)	9A. AMENDMENT OF SOLICITATION NO. N40085-10-R-0014
			X	9B. DATED (SEE ITEM 11) 8-25-11
				10A. MODIFICATION OF CONTRACT/ORDER NO.
				10B. DATED (SEE ITEM 11)
CODE	FACILITY CODE			

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:
 (a) By completing items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor is not, is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

N40085-10-R-0014, Project # 10-0014, Renovate Bldg 799

The hour designated for the receipt of proposals is hereby changed to not later than 1400 on 9 September 2011.

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR		16B. UNITED STATES OF AMERICA	
15C. DATE SIGNED		16C. DATE SIGNED	
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

CONTINUATION SHEET

Priced Line Item 0002 is hereby replaced with the following:

Priced Line Item 0002

All work in the shaded areas on the attached floorplan to include all architectural finishes (i.e. walls, flooring, ceiling, painting, interior doors), mechanical components (i.e. ductwork and grilles/diffusers), electrical components (i.e. switches, outlets, conduit, wire, lights) and any plumbing modifications. Windows or exterior repairs for the shaded areas shall be included in priced line item 0001 (except for the metal patio cover off of classroom #105, and infills that will be constructed in the openings for exterior doors that are to be demoed). All telecommunications work for the entire building will be included in this priced line item. The price for this line item should include all applicable costs, overhead and profit for this work.

1. QUESTION: The Grille, Register & Diffuser Schedule on plan sheet M-601 calls for "surface mount" type; but reflected ceiling plan sheet A-102 shows 2'x2' ACT which would be "lay-in mount". Please clarify requirement.

ANSWER: Provide lay-in mount fixtures in areas indicated to have lay-in ceiling installed.

2. QUESTION: Plan page M-602 "Building Systems Control Diagram" shows the Building Control panel to be NAE Johnson Controls. Plan page M-101 notes a "Variable Refrigerant Flow Heat Pump Control Panel" in mechanical room #132. Is this the NAE Johnson Controls panel or a VRF central control panel provided by the VRF manufacturer?

ANSWER: No, the "Variable Refrigerant Flow Heat Pump Control Panel" in mechanical room #132 is not the NAE Johnson Controls panel. Provide both the NAE Johnson Controls panel and the VRF Control Panel as indicated in the drawings and specifications.

3. QUESTION: It's our understanding that at least 2 of the world's largest variable refrigerant system manufacturers can only provide a BACnet/IP gateway (not a BACnet/MSTP gateway). Plan page M-602 "Building Systems Control Diagram" shows BACnet/MSTP Interface. Is BACnet/IP acceptable?

ANSWER: No, bid as per plans and specifications.

4. QUESTION: It is our understanding that all of the HVAC system is included in Bid Item 0001. Please verify/clarify if this is correct.

ANSWER: The VRF heat pumps themselves are to be included in bid item 0001. Any part of the mechanical system (ductwork, grilles/diffusers, thermostats, fan coil units, associated electrical connections) that supports the rooms in the shaded areas of the floorplan provided via Amendment 0001, are to be included in line item 0002.