

**NAVFAC
SPECIFICATION**

**Repairs and Alterations,
Bays A-D, B-148**

AMENDMENT #0003

IMPORTANT

This amendment should be acknowledged when your proposal is submitted. Failure to acknowledge the amendment may constitute grounds for rejection of the proposal.

If your proposal has been submitted prior to the receipt of this amendment, acknowledgement should be made by telegram, which should state whether the price contained in your proposal is to remain unchanged, is to be decreased by an amount, or is to be increased by an amount. The acknowledgement must be received prior to proposal opening time.

2. AMENDMENT/MODIFICATION NO. 0003	3. EFFECTIVE DATE 9/8/2011	4. REQUISITION/PURCHASE REQ. ---	5. PROJECT NO. (If applicable)
---------------------------------------	-------------------------------	-------------------------------------	--------------------------------

6. ISSUED BY CG MCAS Cherry Point FACILITIES, ROICC B-163, CURTIS ROAD PSC BOX 8006 CHERRY POINT, NC 28533	Code N40085	7. ADMINISTERED BY (If other than item 6.) Code
--	-------------	--

8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code) AMENDMENT MUST BE ACKNOWLEDGED WITH YOUR PROPOSAL	<input checked="" type="checkbox"/>	9A. AMENDMENT OF SOLICITATION PROJECT #
	<input type="checkbox"/>	9B. DATED (SEE ITEM 11)
	<input type="checkbox"/>	10A. MODIFICATION OF CONTRACT/ORDER NO.
	<input type="checkbox"/>	10B. DATED (SEE ITEM 13)
CODE	FACILITY CODE	

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in item 14. The hour and date specified for receipt of Offers is extended is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning 1 copy of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (if required)

**13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS,
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

- A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14. ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
- B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATION CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103 (b).
- C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
- D. OTHER: (specify type of modification and authority)

E. IMPORTANT: Contractor is not is required to sign this document and return **original** to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

REPAIRS AND ALTERATIONS, BAYS A-D, B-148 , MARINE CORPS AIR STATION, CHERRY POINT, NORTH CAROLINA

The purpose of this amendment is to provide the following information:

1. See continuation page for revisions to the scope of work.
2. Best and final offers are due no later than 2pm on 12 September 2011.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR (Same as Item 8)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY	16C. DATE SIGNED
_____ (Signature of person authorized to sign)		_____ (Signature of Contracting Officer)	

Renovate Interior of Office Spaces, Men & Women's Restrooms, Upgrade Fire Suppression System, Bldg. 148

Paragraph O. Modifications to the Fire Suppression System

Subparagraph - Scope of Work

Replace the last bulleted item in its entirety with the following:

"The existing fire alarm panel is a Johnson Controls IFC2-640 with digital voice and speakers and is to remain. Modify the existing fire alarm system to include additional fire alarm devices and appliances, supervision of the fire pump controllers, all tamper switches, and low temperature in the pump room."

Subparagraph - Fire Alarm System Modifications:

Replace the first paragraph in its entirety with the following:

"The existing fire alarm system shall be modified to provide complete supervision of the fire sprinkler system and fire pump room. The existing fire alarm panel is a Johnson Controls IFC2-640 and is to remain."

After the first paragraph, add the following paragraph:

"Provide all fire alarm devices, appliances, and modules for building modifications that are part of this contract. Speaker placement shall meet mass notification requirements. Modify the existing fire alarm system to accommodate the additional fire alarm equipment by extending circuits and providing additional backup batteries and any other work required for a complete and operable fire alarm system meeting all applicable NFPA codes and DOD UFC criteria."

Third paragraph, delete the first sentence as follows:

"Relocate/Place the fire alarm panel in the fire pump room."