

**NAVFAC
SPECIFICATION**

**PROJECT CP0913M,
REPAIR TEQ B-3673 &
PROJECT CP0926R**

AMENDMENT #0002

IMPORTANT

This amendment should be acknowledged when your proposal is submitted. Failure to acknowledge the amendment may constitute grounds for rejection of the proposal.

If your proposal has been submitted prior to the receipt of this amendment, acknowledgement should be made by telegram, which should state whether the price contained in your proposal is to remain unchanged, is to be decreased by an amount, or is to be increased by an amount. The acknowledgement must be received prior to proposal opening time.

2. AMENDMENT/MODIFICATION NO. 0002	3. EFFECTIVE DATE 9/15/2010	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable)
6. ISSUED BY CG MCAS Cherry Point FACILITIES, ROICC B-163, CURTIS ROAD PSC BOX 8006 CHERRY POINT, NC 28533		7. ADMINISTERED BY (If other than item 6.) Code	

8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code) <p style="text-align: center;">AMENDMENT MUST BE ACKNOWLEDGED WITH YOUR PROPOSAL</p>	<input checked="" type="checkbox"/> 9A. AMENDMENT OF SOLICITATION CP0913M CP0926R <input type="checkbox"/> 9B. DATED (SEE ITEM 11) 1/28/2010 <input type="checkbox"/> 10A. MODIFICATION OF CONTRACT/ORDER NO. <input type="checkbox"/> 10B. DATED (SEE ITEM 13)
--	---

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in item 14. The hour and date specified for receipt of Offers is extended is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning 1 copy of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (if required)

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

<input type="checkbox"/>	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14. ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
<input type="checkbox"/>	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATION CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103 (b).
<input type="checkbox"/>	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
<input type="checkbox"/>	D. OTHER: (specify type of modification and authority)

E. IMPORTANT: Contractor is not is required to sign this document and return **original** to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

PROJECT CP0913M, REPAIR TEQ B-3673 & PROJECT CP0926R, IMPROVEMENTS TO TEQ B-3673

This amendment is issued to post the below Questions and Answers:

THE PROPOSAL DUE DATE REMAINS UNCHANGED

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR (Same as Item 8)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY	16C. DATE SIGNED
_____ (Signature of person authorized to sign)		_____ (Signature of Contracting Officer)	

Q) On sheet AD-101 under "General Demolition Notes" it says - "Remove all exterior door complete. Retain electronic lock hardware for reuse." The new hardware schedule does not reflect this note. All hardware sets are shown with new locksets. Please clarify which is correct.

A) The electronic locks are to be removed, stored, and reinstalled. The salvaged electronic locks shall be installed on all exterior doors to Family Suite rooms, Standard Living Unit rooms, and Laundry Rooms. Correct the hardware schedule accordingly.

Q) The plans call for hollow core wood doors, but the specifications call for particleboard core wood doors. Please advise which is correct.

A) The specifications are correct. The amendment changes the door schedule to read "solid core wood doors".

.

Q) On sheet AD-105 under the "Demolition Notes" it says - "12 Remove CMU sufficient to provide 3'6" wide door. See door schedule sheet A-503 for height requirements." Sheet A503 shows a 3' wide door at these locations. Please verify this is correct.

A) The door schedule is correct.

.

Q) Please advise who is to provide the shower curtain, liner, and hooks. It is shown in addendum 2 under the "furniture legend." The manufacturer shown is not a manufacturer that we deal with.

A) The amendment does not address this issue. Shower curtains and rods are specified in section 10 28 13, Toilet Accessories, and are to be provided for all showers and bathtubs.

To clarify, the Concept FF&E Package issued by the amendment is an attachment to specification section 01 30 01, Procurement & Installation of Furniture, Fixtures, & Equipment. It provides design guidance so the prime contractor can develop and provide a Best Valued FF&E Package per Bid Item 0001a of the Basis of Bids. The actual procurement of the FF&E items will be by a Planned Modification Option if the Government exercises that option within 360 days after contract award. Procurement of items in the FF&E Package is not in the base bid.

.

Q) Are the shower prefabricated with grab bars, or are we supposed to supply the grab bars?

A) The showers are not prefabricated, and the grab bars are to be provided.

Q) Hardware set 5 shows an exit device and a lockset. Should it be an exit device with a blank escutcheon?

A) The exit device is to function with the listed lockset.

.

Q) Hardware set 1 has 2 kick plates listed. Are 2 kick plates needed here?

A) Only one kick plate is required

.

Q) Hardware set 2 has a fusible link closers. Fusible link closers are obsolete now. Also, this hardware set is used at the module bathrooms. A hold open closer does not seem to be right here. Please verify a hold open closer is needed.

A) Door closer are not required at this location.

.

Q) Hardware set 4 also has a fusible link closer. This door is at the closet in the offices. Please verify a closer is needed here. It doesn't seem necessary.

A) Door closer are not required at this location.

.

Q) The preamble to the hardware sets talk about a door viewer, but a door viewer is not listed in the hardware sets. Are door viewers needed at the unit entry doors?

A) Yes. Provide door viewers at all exterior doors to Family Suite rooms and Standard Living Unit rooms.

Q) Specification section 08 51 13, paragraph 2.2.8 Finishes states both anodic and organic, which one should it be?

A) The finish shall be anodic.

ADDITIONAL INFORMATION FOR SPECIFICATION SECTION 08 71 00, DOOR HARDWARE

Provide cylinders and cores for new locks with seven pin tumblers. Provide cylinders from Best Lock Corp., with removable core, master key system, "A" Keyway. Stamp each interchangeable core with a key control symbol in a concealed place on the core.